


SECTION A-A

\* SLOPE MAY BE REVERSED TO IMPROVE ACCESS TO GRADE TO SITE.

NOTE:

1. IF DRIVEWAY WIDTH EXCEEDS 15', INSTALL A FULL DEPTH EXPANSION JOINT.
2. THE ACCESS APRON SHALL BE A MINIMUM OF 6" THICK AND SHALL BE PLACED ON 2" OF 5/8" CSTC AND COMPACTED GRADE.
3. MATERIALS- CONCRETE SHALL BE CLASS 3- 3000 PSI.
4. CITY ENGINEER SHALL DETERMINE APPLICABLE COMMERCIAL TYPE ENTRANCE BASED ON LOCATION AND OTHER SITE CONDITIONS.



CITY OF EDMONDS

STANDARD DETAIL

**MULTI-FAMILY/ COMMERCIAL ENTRANCE**

REVISIONS	
APPROVED BY	DATE

DATE	8/17/06	SCALE	NTS	DWG NO.	E 2.27.2
------	---------	-------	-----	---------	----------